

Fire Protection Survey Services™

2403 Fairgrounds Road
Washago, Ontario, Canada, L0K 2B0
Telephone: (249) 359 7231
E-mail: fpss@xplornet.ca Website: www.fpss.ca

Fire Department Water Tanker Shuttle Accreditation

Presented To: North Dundas Township

ACCREDITED FIRE STATIONS

F.S. #1 Morewood (6)
F.S. #2 Chesterville (6)
F.S. #3 Winchester (6)
F.S. #4 South Mountain (6)
F.S. #5 Hallville (6)

Date Test Passed: September 28th 2019

Flow Achieved: 626 I.G.P.M. 2,850 LITERS/MIN.

Two (2) Hour Test Time



Signed: Elaine Rose
Elaine Rose
Partner

This Certificate Expires on: September 1st 2024