

# Winchester Wastewater System

---

Sewage Works # 110001202

## Annual Report

Prepared for: Township of North Dundas

Reporting Period of January 1<sup>st</sup> – December 31<sup>st</sup> 2025

Issued: March 25, 2026

Revision: 0

Operating Authority:



This report has been prepared to meet the requirements set out in:

Document	Document #	Issue Date	Issue Number
Facility ECA	A-500-1199362894	October 13, 2023	1.0
ECA for Municipal Sewage Collection System	180-W601	October 27, 2022	1

## Table of Contents

<b>1</b>	<b>Revision History .....</b>	<b>1</b>
<b>2</b>	<b>Operations and Compliance Reliability Indices .....</b>	<b>1</b>
<b>3</b>	<b>System Process Description.....</b>	<b>1</b>
<b>4</b>	<b>Wastewater System Flows .....</b>	<b>2</b>
<b>5</b>	<b>Raw Sewage Quality .....</b>	<b>3</b>
<b>6</b>	<b>Effluent Quality.....</b>	<b>4</b>
<b>7</b>	<b>Operating Issues .....</b>	<b>9</b>
<b>8</b>	<b>Maintenance .....</b>	<b>10</b>
<b>9</b>	<b>Sludge Generation .....</b>	<b>11</b>
<b>10</b>	<b>Summary of Complaints.....</b>	<b>11</b>
	<b>Appendix A – Performance Assessment Reports.....</b>	<b>A</b>
	<b>Appendix B – Details of Abnormal Sewage Discharge Events .....</b>	<b>B</b>
	<b>Appendix C – ECA Annual Report Requirements .....</b>	<b>C</b>

## 1 Revision History

Date	Rev#	Revisions
2026-03-25	0	Annual Report Issued

## 2 Operations and Compliance Reliability Indices

Compliance Event	# of Events
Environment Canada Inspections	0
Ministry of Environment Inspections	0
Ministry of Labour Inspections	0
Non-Compliance	1
Community Complaints	0
Spills/Overflows/Bypasses	1/0/0
Sewer Main Blockages	1

## 3 System Process Description

Winchester’s wastewater system consists of a gravity fed sanitary sewage collection system, four pumping stations and a wastewater treatment lagoon. The main sewage pumping station is located on Ottawa Street and discharges directly to the lagoons. There are also two pumping stations located on Main Street and one on St. Lawrence Street which pump wastewater to the Ottawa St. SPS. Aluminum sulphate is dosed continuously for phosphorus control as wastewater is pumped to the lagoons.

The Township of North Dundas initiated a Class Environmental Assessment of Winchester’s wastewater treatment system in 2017 to address various operational challenges, such as hydraulic capacity, discharge constraints and treatment capabilities in order to ensure that increased wastewater flows from future growth can be effectively accommodated. The construction of the SAGR system commenced in 2023. Commissioning of the new treatment system started in the spring of 2025 and will be concluded in early 2026. The SAGR treatment system is expected to reach substantial completion in April 2026.


The wastewater treatment system consists of a five cell lagoon system and two Submerged Attached Growth Reactors (SAGRs) with a rated capacity of 2,220 m<sup>3</sup>/d. The three primary facultative treatment cells are operated in parallel (Cells 1, 2 and 3). Wastewater flows from the primary cells to Cell 4, then to Cell 5 and finally to the SAGRs (Cells 6A and 6B) before being discharged. When the system is not discharging to the river, the SAGR effluent is recirculated to Cell 4 or Cell 2. Seasonal discharge of effluent from the lagoons is permitted at specific times during the spring and fall each year. As of 2026, the effluent from the lagoons will be discharged from November 1 to April 30 each year. During the regulated discharge period, SAGR effluent is conveyed over 7.3 kilometers to an outlet in the South Nation River.

## 4 Wastewater System Flows


The hydraulic flows reaching the sewage lagoons in 2025 averaged 1358.3 m<sup>3</sup>/day which represents 61.2% of the 2,220 m<sup>3</sup>/day design capacity.

### 4.1 Raw Flows

2025 Raw Flows (m<sup>3</sup>/d):



Annual Raw Flow Comparison (m<sup>3</sup>):




### 4.2 Effluent Flow

Discharge Period	Start Date	End Date	Volume Discharged (m <sup>3</sup> )
Spring Discharge	April 8, 2025	April 30, 2025	138,903
Fall Discharge	November 3, 2025	December 15, 2025	151,442
<b>Total Flow Discharged</b>			<b>290,345</b>


## 5 Raw Sewage Quality

2025 monthly results are available in Appendix A – Performance Assessment Reports.


### Annual Comparison (mg/L):




### 5.1 Biochemical Oxygen Demand (5-Day)




### 5.2 Total Suspended Solids



### 5.3 Total Phosphorus



### 5.4 Total Kjeldahl Nitrogen



## 6 Effluent Quality

The results from the spring and fall discharge periods are tabulated below. Please refer to the Performance Reports in Appendix A and the ‘Operational Issues’ section of this report for further information.

### 6.1 Effluent Quality Assurance or Control Measures

This system is part of the Ontario Clean Water Agency’s Nation Valley Cluster. The cluster is supported by the Eastern Regional Hub and corporate resources. Operational Services are provided by OCWA employees who work in the community. The system is operated to meet compliance with applicable regulations. The system has comprehensive manuals detailing operations, maintenance, instrumentation, and emergency procedures. All procedures are treated as active documents and are updated as required. These documents are also part of OCWA’s Quality & Environmental Management System.

Effluent control measures include pre-discharge sampling and testing of lagoon cell contents prior to seasonal discharges. The samples are collected by OCWA’s competent and licensed staff using approved methods and protocols for sampling including those specified in the Ministry’s Procedure F-10-1 “Procedures for Sampling and Analysis Requirements for Municipal and Private Sewage Treatment Works”, the Ministry’s publication “Protocol for the Sampling and Analysis of Industrial/Municipal Wastewater” and the publication “Standard Methods for the Examination of Water and Wastewater”.

All effluent samples collected during the reporting period to meet legislated sampling requirements were submitted to Caduceon Environmental Laboratories in Ottawa for analysis, with the exception of pH,

temperature, dissolved oxygen and unionized ammonia. Caduceon is accredited by the Canadian Association for Laboratory Accreditation (CALA). Accredited labs must meet strict provincial guidelines including an extensive quality assurance/quality control program. By choosing this laboratory, OCWA is ensuring appropriate control measures are undertaken during laboratory testing. The pH, temperature and dissolved oxygen samples are analyzed in the field at the time of sample collection by certified operators to ensure accuracy and precision of the results obtained. Un-ionized ammonia was calculated using the total ammonia nitrogen concentration, pH and temperature as required by the facility’s ECA.

OCWA uses several computer systems which include:


- Process Data Management (PDM)
  - This database consolidates all operational data from a variety of sources including field data, online instrumentation, and electronically uploaded lab test results for reporting, tracking and analysis.
- Maximo – OCWA’s Work Management System (WMS)
  - This program is used to track and schedule maintenance activities for all equipment in the system. It is also used to assign specific operational tasks to staff.
- Wonderware (OUTPOST5)/SCADA
  - OCWA’s SCADA system allows for process automation, process adjustments, data logging, trending review and remote alarming.

The operations team also has access to a network of compliance and process specialists to assist with process issues.

## 6.2 Carbonaceous Biochemical Oxygen Demand (5-Day)

Discharge Period	Seasonal Average (mg/L)	Objective (mg/L)	Objective Exceedance (Y/N)	Limit (mg/L)	Limit Exceedance (Y/N)
Spring	3.2	25.0	N	30.0	N
Fall	3.0	25.0	N	30.0	N


### Effluent CBOD<sub>5</sub> Results:



### 6.3 Total Suspended Solids

Discharge Period	Seasonal Average (mg/L)	Objective (mg/L)	Objective Exceedance (Y/N)	Limit (mg/L)	Limit Exceedance (Y/N)
Spring	7.2	30.0	N	40.0	N
Fall	11.6	30.0	N	40.0	N


Effluent TSS Results:



### 6.4 Total Phosphorus

Discharge Period	Seasonal Average (mg/L)	Objective (mg/L)	Objective Exceedance (Y/N)	Limit (mg/L)	Limit Exceedance (Y/N)
Spring	0.37	0.8	N	1.0	N
Fall	0.36	0.8	N	1.0	N

Effluent TP Results:




### 6.5 Total Ammonia Nitrogen


Discharge Period	Seasonal Average (mg/L)	Objective (mg/L)	Objective Exceedance (Y/N)	Limit (mg/L)	Limit Exceedance (Y/N)
Spring	15.01	12.0	Y*	15.0	Y*
Fall	1.83	4.0	N	7.0	N

\*Please refer to the 'Operating Issues' section of this report for details.

#### Effluent TAN Results for Spring Discharge Period:



#### Effluent TAN Results for Fall Discharge Period:



### 6.6 Undissociated Hydrogen Sulphide

Discharge Period	Seasonal Average (mg/L)	Objective (mg/L)	Objective Exceedance (Y/N)	Limit (mg/L)	Limit Exceedance (Y/N)
Spring	Non-Detectable	Non-Detectable	N	0.02	N
Fall	Non-Detectable	Non-Detectable	N	-	N/A

**Effluent Undissociated H<sub>2</sub>S Results for Spring Discharge Period:**

	Sample 1	Sample 2	Sample 3	Sample 4	Sample 5	Average
S <sup>2-</sup> (mg/L)	< 0.01	< 0.16	< 0.08	< 0.01	< 0.08	ND
pH	7.9	7.8	7.8	7.7	7.8	N/A
Temp	6.0	8.6	9.9	11.7	13.1	N/A
% Undissociated H <sub>2</sub> S (from table)	18.8	20.5	19.7	22.4	18.2	N/A
Undissociated H <sub>2</sub> S (mg/L)	ND	ND	ND	ND	ND	ND

**Effluent Undissociated H<sub>2</sub>S Results for Fall Discharge Period:**


	Sample 1	Sample 2	Sample 3	Sample 4	Sample 5	Average
S <sup>2-</sup> (mg/L)	< 0.01	< 0.08	< 0.08	< 0.80	< 0.08	ND
pH	8.5	8.1	8.0	8	7.7	N/A
Temp	9.4	9.3	6.6	6.6	9.5	N/A
% Undissociated H <sub>2</sub> S (from table)	4.8	11.3	14.9	14.9	23.9	N/A
Undissociated H <sub>2</sub> S (mg/L)	ND	ND	ND	ND	ND	ND

**6.7 pH**

Discharge Period	Seasonal Average	Objective	Objective Exceedance (Y/N)	Limit	Limit Exceedance (Y/N)
Spring	7.8	6.5 – 8.1	N	6.0 – 9.5	N
Fall	8.1	6.5 – 8.1	Y*	6.0 – 9.5	N

\*Please refer to the 'Operating Issues' section of this report for details.


**Effluent pH Results:**



### 6.8 Dissolved Oxygen

There are no dissolved oxygen objectives or limits specified in the facility’s ECA.

#### Effluent D.O. Results:



## 7 Operating Issues

The pH remained within the limits in all effluent samples collected in 2025 but exceeded the upper objective in the first sample collected for the fall discharge.

### 7.1 Effluent Quality Non-Compliance Summary

Date	Exceedance of	Limit	Value	Corrective Action
Spring Discharge	TAN Limit	15 mg/L	15.01 mg/L	<p>Five effluent samples were collected over the course of the spring discharge. While a low concentration of TAN was detected in the first effluent sample, the concentration was above the limit for the remainder of the samples collected. It should be noted that effluent was discharged from the lagoon at a relatively low flow rate (~74 l/s) for the duration of the discharge.</p> <p>Winchester’s lagoon system has been under construction for the installation of a new SAGR treatment system, which provides nitrification and thereby reduces TAN concentrations in the final effluent.</p>

### 7.2 Summary of Abnormal Sewage Discharge Events

Abnormal discharge events include bypasses, overflows, and spills of sewage. No bypasses, no overflows and one spills of sewage occurred during the reporting period. Summary Details are included in Appendix B.

### 7.3 Spills (Other than Sewage)

Date	Location	Details	Volume (m3)	Start Date and Time	End Date and Time
None to report.					

## 8 Maintenance

OCWA uses a risk-based preventative maintenance framework that ensures assets are maintained to manufacturer’s and/or industry standards. Maintenance is completed using various tools and operational supports.

OCWA uses a Workplace Management System (WMS). WMS is a maintenance tracking system that can generate work orders as well as provide summaries of completed and scheduled work. During the year, the operating authority generates scheduled work orders on a planned frequency. This ensures routine and preventive maintenance is carried out. Emergency and capital repair maintenance is added to the system and completed as required.

Routine planned maintenance activities scheduled in WMS include:

- Inspecting, adjusting and calibrating process control equipment to ensure proper operation of sewage collection systems, pumps, chemical feeders, and all other equipment installed at the facilities.
- Carrying out a routine maintenance program including greasing and oiling as specified in the lubrication schedule.

Planned maintenance activities are communicated to the individuals responsible for completing the task through the issuance of WMS work orders. Work orders are generated automatically on a schedule based on the manufacturer’s recommendations and/or site specific operational and maintenance needs, and are assigned directly to the appropriate operations personnel. Work orders are electronically completed in WMS by the person responsible for completing the task. Unplanned maintenance is carried out as needed.

Suggested capital projects and major maintenance recommendations are provided to the Township of North Dundas annually by OCWA. This list is developed the operations team and provides recommendations for facility components requiring upgrading or improvement.

### 8.1 Maintenance and Repair Summary

Description
<ul style="list-style-type: none"> <li>- Performed routine sewer flushing &amp; wet well cleanings</li> <li>- Completed annual generator maintenance</li> <li>- Replaced water pump on generator at Ottawa St. SPS</li> <li>- Completed annual flow meter calibration</li> <li>- Completed annual backflow preventer inspection</li> <li>- Installed new flow hour meter for pump #3 at Ottawa St. SPS</li> <li>- Installed new UPS units in all outpost panels</li> <li>- Replaced wet well ladders at Main St. SPS and St-Lawrence St. SPS</li> </ul>

Description
<ul style="list-style-type: none"> <li>- Installed new check valves on pump 1 and 2 at Ottawa St SPS</li> <li>- Replaced exterior doors (1 x single door and 2 x double door) at Ottawa St SPS</li> <li>- Replaced double exterior door for pump room at lagoon</li> <li>- Replaced heater in discharge pump room at lagoon</li> <li>- Installed two new sewer connections / clean out on Alexandre St.</li> <li>- Cleaned sewer blockage in between last manhole and Main St SPS with vacuum truck</li> <li>- Repaired sewer main break on Main St. SPS force main</li> </ul>

## 8.2 Flow Meter Calibration and Maintenance

Location	Date of Calibration	Additional Maintenance
Lagoon Effluent Flow Meter	April 15, 2025	n/a

## 8.3 Authorized Alterations in Collection System

Work Order	Details	Significant Drinking Water Threat (Y/N)
None to Report		

## 8.4 Notice of Modifications

Date	Process	Modification	Status
Substantial completion expected in April 2026	Wastewater Treatment	Construction of SAGR treatment system Commissioning began in 2025	Ongoing

# 9 Sludge Generation

Sludge depth is monitored periodically, and plans for sludge removal are made as required for optimal operation of the lagoon system. Sludge levels in all ponds were measured in 2025. The measurements were as follows:

Lagoon Cell	Sludge Depth
Cell 1	4" – 6"
Cell 2	3" – 6"
Cell 3	3" – 6"
Cell 4	4" – 8"
Cell 5	0 "

## 9.1 Sludge Disposal Summary

Sludge from Cell 2 & Cell 3 was removed in the early 2000s. Sludge was removed from Cell 5 in 2023, stored onsite in geotubes to dry, and then hauled with the geotubes to the municipal landfill (Boyne Road) in 2025.

# 10 Summary of Complaints

There were no complaints received in 2025.

---

## **Appendix A – Performance Assessment Reports**

### WINCHESTER WASTEWATER PERFORMANCE ASSESSMENT REPORT

MONTH	FLOWS					Avg. Alum Dosage (mg/L)	CBOD5			TOTAL SUSPENDED SOLIDS			PHOSPHORUS			TKN
	TOTAL FLOW m <sup>3</sup>	AVG DAY FLOW m <sup>3</sup>	MAX DAY FLOW m <sup>3</sup>	EFFLUENT FLOW m <sup>3</sup>	DISCHARGE DURATION (days)		AVG RAW BOD5 (mg/L)	AVG EFF CBOD5 (mg/L)	PERCENT REMOVAL (%)	AVG RAW TSS (mg/L)	AVG EFF TSS (mg/L)	PERCENT REMOVAL (%)	AVG RAW PHOS. (mg/L)	AVG EFF PHOS. (mg/L)	PERCENT REMOVAL (%)	AVG RAW TKN (mg/L)
JAN	43,055	1,389	2,144			106.7	208			262			4.22			54.2
FEB	28,955	1,034	1,367			107.0	264			155			6.36			53.4
MAR	77,629	2,504	5,912			106.1	119			140			5.22			38.2
APR	76,953	2,565	4,982	138,903	23	108.8	59	3.2		85	7.2		3.10	0.37		32.9
MAY	47,436	1,530	1,965			106.6	95			110			5.50			53.9
JUN	40,271	1,342	1,681			106.4	84			195			5.41			47.5
JUL	31,353	1,011	1,147			109.1	181			320			7.09			73.6
AUG	25,214	813	918			110.1	150			175			6.29			59.1
SEP	24,531	818	985			110.9	134			85			5.58			75.6
OCT	27,084	874	1,794			108.7	226			280			7.13			62.8
NOV	37,518	1,251	1,663	95,400	28	109.4	102	3.0		105	8.3		4.86	0.36		42.6
DEC	35,798	1,155	1,638	56,042	15	110.1	160	3.0		125	16.5		5.85	0.36		51.6
TOTAL	495,796		SPRING	138,903	23											
TOTAL			FALL	151,442	43											
AVG		1,358				108.3	148.5	3.1	97.9	170	9.4	94.5	5.55	0.36	93.5	53.8
MAX			5,912				264			320			7.13			75.6
CRITERIA		<b>2,220</b>		SPRING	<b>21</b>			<b>30</b>			<b>40</b>			<b>1</b>		
CRITERIA				FALL	<b>21</b>			<b>30</b>			<b>40</b>			<b>1</b>		

Note: PERCENT REMOVAL BASED ON 12 MONTHS OF RAW SEWAGE COMPOSITE SAMPLES

### EFFLUENT LOADING

TOTAL LOADING	SPRING	FALL	TOTAL	ECA LIMIT
CBOD (kg)	444	454	<b>899</b>	<b>24,309</b>
SS (kg)	1,000	1,757	<b>2,757</b>	<b>32,412</b>
TP (kg)	51	55	<b>106</b>	<b>810.3</b>
NH <sub>3</sub> (kg)	2,085	277	<b>2,362</b>	-

**EFFLUENT SAMPLE RESULTS – SPRING**

SAMPLE	SAMPLE RESULTS	SPRING					Average	138,903 m <sup>3</sup>	
		08-Apr	16-Apr	22-Apr	27-Apr	30-Apr		C of A Objective	C of A Limit
5X/DISCHARGE	DATE	08-Apr	16-Apr	22-Apr	27-Apr	30-Apr	Average		
	CBOD (mg/L)	<3	4	<3	<3	<3	3.2	25	30
	TSS (mg/L)	5	7	9	6	9	7.2	30	40
	TP (mg/L)	0.03	0.49	0.47	0.42	0.42	0.37	0.8	1
	DO (mg/L)	10.5	5.0	4.1	3.6	2.8	5.2	-	-
	N-NH <sub>3</sub> (mg/L)	3.36	18.4	20.6	16.9	15.8	15.01	12	15
	Un-ionized NH <sub>3</sub> (mg/L)*	0.04	0.19	0.24	0.18	0.23			
	NO <sub>2</sub> (mg/L)	<0.4	<0.4	<0.40	<0.40	<0.05			
	NO <sub>3</sub> (mg/L)	<0.4	<0.4	<0.40	<0.40	<0.05			
	<i>E.coli</i> (cfu/100 mL)	<2	<10	<10	<10	10			

\* Un-ionized NH<sub>3</sub> based on in-house calculation

	08-Apr	16-Apr	22-Apr	28-Apr	30-Apr	Average	Objective	Limit
S2- (mg/L)	<0.01	<0.16	<0.08	<0.01	<0.08	ND	N/A	N/A
pH	7.9	7.8	7.8	7.7	7.8	7.80	6.5 - 8.1	6.0 - 9.5
Temp	6.0	8.6	9.9	11.7	13.1	N/A	N/A	N/A
% Undissociated H <sub>2</sub> S	18.80	20.5	19.7	22.40	18.2	N/A	N/A	N/A
Undissociated H <sub>2</sub> S*	ND	ND	ND	ND	ND	ND	ND	0.02

\*Lab analysis could not detect hydrogen sulphide above the reporting limit in any effluent samples, and no odour was present during spring discharge

**PRE-DISCHARGE RESULTS – SPRING**

	Cell 1*	Cell 2*	Cell 3	Cell 4	Cell 5	Comments
CBOD (mg/L)	-	-	10	16	7	*Cell 1 & Cell 2 not discharged in spring
TSS (mg/L)	-	-	16	39	22	
TP (mg/L)	-	-	0.39	1.17	0.63	
NH <sub>3</sub> (mg/L)	-	-	12.6	21.4	14.6	
TKN (mg/L)	-	-	18.8	30.6	18.0	
H <sub>2</sub> S (mg/L)	-	-	<0.08	<0.16	<0.08	
<i>E.coli</i> (cfu/100 mL)	-	-	10600	30	500	

**EFFLUENT SAMPLE RESULTS – FALL**

SAMPLE	SAMPLE RESULTS	FALL						151,442 m <sup>3</sup>	
		DATE	03-Nov	10-Nov	24-Nov	08-Dec	15-Dec	Average	C of A Objective
5X/DISCHARGE	CBOD (mg/L)	< 3	< 3	< 3	< 3	3	3.0	25	30
	TSS (mg/L)	7	7	11	22	11	11.6	30	40
	TP (mg/L)	0.29	0.35	0.45	0.38	0.35	0.36	0.8	1
	DO (mg/L)	2.4	11.42	9.46	10.66	6.6	8.1	-	-
	N-NH <sub>3</sub> (mg/L)	0.05	0.9	5.52	0.35	2.33	1.83	4	7
	Un-ionized NH <sub>3</sub> (mg/L)*	0.003	0.0195	0.0771	0.005	0.021	0.03		
	NO <sub>2</sub> (mg/L)	< 0.40	0.91	< 0.40	1.08	< 0.40			
	NO <sub>3</sub> (mg/L)	5.98	5.41	7.32	8.75	12.4			
	<i>E.coli</i> (cfu/100 mL)	20	40	< 10	60	20			

\* Un-ionized NH<sub>3</sub> based on in-house calculation

	08-Apr	16-Apr	22-Apr	28-Apr	30-Apr	Average	Objective	Limit
S2- (mg/L)	<0.01	<0.16	<0.08	<0.01	<0.08	ND	N/A	N/A
pH	7.9	7.8	7.8	7.7	7.8	7.80	6.5 - 8.1	6.0 - 9.5
Temp	6.0	8.6	9.9	11.7	13.1	N/A	N/A	N/A
% Undissociated H <sub>2</sub> S	18.80	20.5	19.7	22.40	18.2	N/A	N/A	N/A
Undissociated H <sub>2</sub> S*	ND	ND	ND	ND	ND	ND	ND	0.02

\*Lab analysis could not detect hydrogen sulphide above the reporting limit in any effluent samples, and no odour was present during fall discharge

**PRE-DISCHARGE RESULTS - FALL**

	Cell 1	Cell 2	Cell 3	Cell 4	Cell 5	Comments
CBOD (mg/L)	20	19	9	6	5	
TSS	80	56	30	30	18	
TP (mg/L)	0.81	0.69	0.46	1.15	0.74	
pH	8.3	8.6	7.4	7.9	8.4	
Temperature (°C)	14.7	14.1	15.0	16.7	15.5	
NH <sub>3</sub> (mg/L)	6.17	2.70	15.30	2.78	1.30	
Un-ionized ammonia (mg/L)	0.002	0.000	15.300	0.000	0.000	
TKN (mg/L)	14.9	11.2	22.7	7.2	3.7	
H <sub>2</sub> S (mg/L)	<0.16	<0.01	<0.08	<0.08	<0.04	
<i>E.coli</i> (cfu/100 mL)	30000	2700	800	1300	240	

**Un-ionized Ammonia Calculation**

Sample Date	Temperature (°C)	Degrees Kelvin	Dissociation Constant pKa	Sample pH on-site	Fraction of Un-ionized Ammonia	Total Ammonia (mg/L) (NH <sub>3</sub> +NH <sub>4</sub> +as N)	Un-ionized Ammonia (mg/L)
08-Apr	6.0	279.15	9.87	7.9	0.0106	3.36	0.036
16-Apr	8.6	281.75	9.78	7.8	0.0104	18.4	0.191
22-Apr	9.9	283.05	9.73	7.8	0.0115	20.6	0.237
28-Apr	11.7	284.85	9.67	7.7	0.0105	16.9	0.178
30-Apr	13.1	286.25	9.63	7.8	0.0147	15.8	0.232
03-Nov	9.4	282.55	9.75	8.5	0.0530	0.05	0.003
10-Nov	9.3	282.45	9.76	8.1	0.0216	0.9	0.0195
24-Nov	6.6	279.75	9.85	8	0.0140	5.52	0.0771
08-Dec	6.6	279.75	9.85	8	0.0140	0.35	0.0049
15-Dec	9.5	282.65	9.75	7.7	0.0089	2.33	0.021

---

## **Appendix B – Details of Abnormal Sewage Discharge Events**

## Event Details Summary

### Facility Bypass

Date	Location	Details	Volume (m <sup>3</sup> )	Start Time	End Time	Duration (h)	Discharge Receiver	Disinfection Provided
None to report.								

### Facility Overflow

Date	Location	Details	Volume (m <sup>3</sup> )	Start Time	End Time	Duration (h)	Discharge Receiver	Disinfection Provided
None to report.								

### Collection Overflow

Date	Location	Details	Volume (m <sup>3</sup> )	Start Time	End Time	Duration (h)	Discharge Receiver	Disinfection Provided
None to report.								

### Spills of Sewage

Date	Location	Details	Volume (m <sup>3</sup> )	Start Time	End Time	Duration (h)	Discharge Receiver	Disinfection Provided
April 16, 2025	Near 546 Main St. Winchester	Force main break	2.1	8:00	16:00	8	N/A	No

## Collection System Monitoring Data

Event Date	Event Location	Volume (m <sup>3</sup> )	Parameter	mg/L	Source Loading (kg)	Any Adverse Impacts & Corrective Actions
April 16, 2025	Near 546 Main St. Winchester	2.1	BOD5	77	0.16	No adverse impacts from the spill. Corrective action was to shut off Main St. SPS pumps after force main leak was discovered. Hydrovac truck on site to bypass inflow from Main St. SPS for the duration of the repair.
			Total Suspended Solids	380	0.80	
			Total Phosphorus	1.55	0.003	
			Total Kjeldahl Nitrogen (TKN)	19	0.04	
			E. coli	1,200,000		

---

## **Appendix C – ECA Annual Report Requirements**

<b>Facility ECA #A-500-1199362894</b> <b>Section 11(4)</b>	<b>Section in Report</b>
6.a. A summary and interpretation of all Influent, monitoring data, and a review of the historical trend of the sewage characteristics and flow rates;	Wastewater System Flows Raw Sewage Quality Appendix A
6.b. A summary and interpretation of all Final Effluent monitoring data, including concentration, flow rates, loading and a comparison to the design objectives and compliance limits in this Approval, including an overview of the success and adequacy of the Works;	Wastewater System Flows Effluent Quality Appendix A
4.c. A summary of all operating issues encountered and corrective actions taken;	Operating Issues
4.d. A summary of all normal and emergency repairs and maintenance activities carried out on any major structure, equipment, apparatus or mechanism forming part of the Works;	Maintenance
4.e. A summary of any effluent quality assurance or control measures undertaken;	Effluent Quality
4.f. A summary of the calibration and maintenance carried out on all Influent, Imported Sewage and Final Effluent monitoring equipment to ensure that the accuracy is within the tolerance of that equipment as required in this Approval or recommended by the manufacturer;	Maintenance
4.g. A summary of efforts made to achieve the design objectives in this Approval, including an assessment of the issues and recommendations for pro-active actions if any are required under the following situations: a. when any of the design objectives is not achieved more than 50% of the time in a year, or there is an increasing trend in deterioration of Final Effluent quality; b. when the Annual Average Daily Influent Flow reaches 80% of the Rated Capacity;	Wastewater System Flows Effluent Quality Operating Issues
4.h. A tabulation of the volume of sludge generated, an outline of anticipated volumes to be generated in the next reporting period and a summary of the locations to where the sludge was disposed and a tabulation of the measured volume of sludge accumulated in the lagoon cells in five year intervals and the estimated volume in the interim years and when sludge was disposed of during the reporting period, a summary of disposal locations and volumes of sludge disposed at each location;	Sludge Generation
4.i. A summary of any complaints received and any steps taken to address the complaints;	Summary of Complaints
4.j. A summary of all Bypasses, Overflows, other situations outside Normal Operating Conditions and spills within the meaning of Part X of EPA and abnormal discharge events;	Operating Issues Appendix B
4.k. A summary of all Notice of Modifications to Sewage Works completed under Paragraph 1.d. of Condition 10, including a report on status of implementation of all modification;	Maintenance
4.l. A summary of efforts made to achieve conformance with Procedure F-5-1 including but not limited to projects undertaken and completed in the sanitary sewer system that result in overall Bypass/Overflow elimination including expenditures and proposed projects to eliminate Bypass/Overflows with estimated budget forecast for the year following that for which the report is submitted;	Maintenance Operating Issues
4.m. Any changes or updates to the schedule for the completion of construction and commissioning operation of major process(es) / equipment groups in the Proposed Works;	Maintenance Operating Issues
<b>Collection ECA #180-W601</b> <b>Schedule E</b>	
4.6.3 If applicable, includes a summary of all required monitoring data along with an interpretation of the data and any conclusion drawn from the data evaluation about the need for future modifications to the Authorized System or system operations.	Operating Issues
4.6.4 Includes a summary of any operating problems encountered and corrective actions taken.	Operating Issues

<b>Collection ECA #180-W601 Schedule E</b>	
4.6.5 Includes a summary of all calibration, maintenance, and repairs carried out on any major structure, Equipment, apparatus, mechanism, or thing forming part of the Municipal Sewage Collection System.	Maintenance
4.6.6 Includes a summary of any complaints related to the Sewage Works received during the reporting period and any steps taken to address the complaints.	Summary of Complaints
4.6.7 Includes a summary of all Alterations to the Authorized System within the reporting period that are authorized by this Approval including a list of Alterations that pose a Significant Drinking Water Threat.	Maintenance
4.6.8 Includes a summary of all Collection System Overflow(s) and Spill(s) of Sewage, including: a) Dates; b) Volumes and durations; c) If applicable, loadings for total suspended solids, BOD, total phosphorus, and total Kjeldahl nitrogen, and sampling results for E.coli; d) Disinfection, if any; and e) Any adverse impact(s) and any corrective actions, if applicable.	Operating Issues Appendix B
4.6.9 Includes a summary of efforts made to reduce Collection System Overflows, Spills, STP Overflows, and/or STP Bypasses, including the following items, as applicable: a) A description of projects undertaken and completed in the Authorized System that result in overall overflow reduction or elimination including expenditures and proposed projects to eliminate overflows with estimated budget forecast for the year following that for which the report is submitted. b) Details of the establishment and maintenance of a PPCP, including a summary of project progresses compared to the PPCP’s timelines. c) An assessment of the effectiveness of each action taken. d) An assessment of the ability to meet Procedure F-5-1 or Procedure F-5-5 objectives (as applicable) and if able to meet the objectives, an overview of next steps and estimated timelines to meet the objectives. e) Public reporting approach including proactive efforts.	Maintenance Operating Issues